From:	Philip Mudd
To:	"danny.mapili@gsa.gov"; "tony.lopacki@gsa.gov"; Todd Williams; Joshua Hill; Terry Lamb Sr.
Subject:	Water filter"s
Date:	Friday, March 25, 2016 9:34:16 AM
Attachments:	Aqua-Pure 117.jpg Everpure 10 inch housing.jpg AP117 - Aqua Pure Water Filters & Systems.pdf plumbing fixture specification.pdf

---

Danny

Can you make sure these details get added to the drawings. The CUNO brand that is aqua-pure's AP-11T has failed repeatedly, we changed to the EVERPURE E-Series housing. The "O" rings do not fail, they have a much more substantial construction and a sturdy mounting system. The 4 west galley has an example and I have sample of both the filter & the housing. Our building engineers prefer the EVERPURE E-Series housing

Phil

Federal Energy Regulatory Commission
888 First Street NE 41-72
Washington DC 20426
Philip.mudd@ferc.gov
202-502-646 desk
202-641-6001 cell